



- A \_\_\_\_\_ WIDTH OF PLENUM
- B \_\_\_\_\_ HEIGHT OF PLENUM
- C \_\_\_\_\_ WIDTH OF COIL
- D \_\_\_\_\_ HEIGHT OF COIL
- E \_\_\_\_\_ HEIGHT OF FIRST ROW
- F \_\_\_\_\_ DRAIN PAN TO FIRST ROW
- G \_\_\_\_\_ COIL TO LIGHTS
- H \_\_\_\_\_ NUMBER OF DE 181 VO FIXTURES
- I \_\_\_\_\_ NUMBER OF DE 241 VO FIXTURES
- J \_\_\_\_\_ NUMBER OF DE 301 VO FIXTURES
- K \_\_\_\_\_ AMPS = 2/3 AMP PER FIXTURE @ 115 VOLTS
- L \_\_\_\_\_ AMPS = 1/3 AMP PER FIXTURES @ 220 VOLTS

TOTAL AMPS

NOTE: UP TO 10 FIXTURES CAN BE WIRED END TO END

PROJECT	
ENGINEER	
LOCATION	
S-A REP	
DATE	

<b>A</b>	8/10 00	FIRST ISSUE	RMC
REV	DATE		DFT
NEXT ASSY			WT.
SUGGESTED LAYOUT: 1 ROW SYSTEMS OPEN PLENUM SYSTEMS DE SERIES FIXTURES			
<b>STERIL-AIRE</b>		DRAWING NO. 9711195	REV. A